


Eyewasher Polypropylene Bowl



requirements of the regulations:

- EN 15154-1 Standards for shower devices for the body connected to the water network and according to which the minimum flow rate of the sprayer must be at least 100 l / min. Emergency showers DILUVIO a flow rate of more than 120 l / min at 0.3 MPa.
- EN 15154-2 Standards for eyewash units connected to the water mains and according to which the minimum flow rate of the eyewash must be at least 6 l / min. DILUVIO eye drops have a flow rate of over 14 l/min at 0.3 MPa.
- UNI9608 regulations governing the use of emergency showers and eyewashes
- UNI10271 Regulations governing the use of eyewash / laptop washers
- UNI7546 / 2 UNI7546 / 3 UNI7546 / 4 which requires the presence of an individual captive cartel for the shower and another for the emergency eyewash.
- Din 12899 PART 2
- ANSI Z358.1-2004 (American National Sanitation Institute).

Documents

[Technical Data Sheets - ES \(634.1 Kb\)](#)